



NOTES:

1. APPLY BOND-BREAKER BETWEEN SECOND POUR & WALL POUR PER MANUFACTURER'S REQUIREMENTS.
2. SECOND POUR CAN BE PLACED AFTER STRESSING.
3. THE PS=Ø RELIEF JOINT TO REMAIN OPEN FOR XX DAYS.
4. AFTER THE TIME PERIOD SPECIFIED ABOVE, THE PS=Ø COUPLERS AND JOINT TO BE GROUTED PER MANUFACTURER'S REQUIREMENTS.
5. SEE PS=Ø MANUFACTURE DATA FOR MORE INFORMATION.

**PS=Ø RELIEF JOINT @ TOP OF WALL w/TEMPORARY STRESSING STRIP**